

Inspecta Estonia OÜ has granted a product certificate to attest that the construction product

Isotex ceiling panel covered with paper

placed on the market by

Skano Fiberboard OÜ
Rääma 31, 80044 Pärnu, ESTONIA

and produced in the factory

Skano Fiberboard OÜ
Rääma 31, 80044 Pärnu, ESTONIA

has following properties

Reaction to fire of the panel	D-s1, d0 (classification according to EN 13501-1:2007+A1:2009)
Thickness of the panel	12 mm
Density of the panel	250 kg/m ³

The manufacturer has functioning FPC implemented according to the requirements of standard **EN 13171:2012**.

The manufacturer is testing the samples taken at the factory in accordance with prescribed test plan. Inspecta Estonia OÜ has performed type testing, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate is issued on **24.10.2013** and remains valid until **23.10.2018**, as long as the manufacturing conditions in the factory or the FPC itself are not modified significantly. The validity of the certificate can be checked on the Internet at www.inspecta.com.

Tallinn 16.05.2017

Tõnu Roosaar
Manager



Inspecta Estonia OÜ
Teaduspargi 8, 12618 Tallinn, Estonia
Tel +372 659 9470 Fax +372 659 9479
estonia@inspecta.com

Group headquarters: Inspecta Group Oy, Helsinki, Finland

TRUST & QUALITY www.inspecta.com